

## **2018 International Fire Code**

**508.1.3 (IBC [F] 911.1.3) Size.** The *fire command center* shall be not less than 0.015 percent of the total building area of the facility served or 200 square feet (8.9 19 m ) in area, whichever is greater, with a minimum dimension of 0.7 times the square root of the room area, or 8 10 feet (2438 3048 mm), whichever is greater.